

SDoC Identification Number¹: UFL150

Issuer details

Name ² (of New Zealand manufacturer or importer): ORBIT TRADING LIMITED Telephone: +6499744868 New Zealand Company No. (if applicable): 5124281 Email Address: info@ledx.co.nz	Contact Address: Unit 1, 18 Moselle Avenue, Henderson, Auckland, 0610 New Zealand
---	---

Medium Risk Article – Details³ (Product name, type, rating, brand, model, batch numbers, and serial numbers, as applicable):

Product Type: LED Floodlights
 Brand: LEDx Lighting Solutions (150 Watts Ultra Flood Lights)
 Model: UFL150
 Rated: AC 100-240~50/60Hz, 150W, Class I, IP65 Ta:50°C, CCT 2700K-6500K
 (This model is electrically & mechanically identical factory model mentioned in the test report)

The Medium Risk Article listed above, fully complies:

With cited standard(s), as listed⁴: Standard number and issue year: AS/NZS 60598.1:2003 Edition / Amendment status: - Standard title: Luminaires - Part 1: General requirements and tests AS/NZS ZZ modified Yes <input type="checkbox"/> No <input type="checkbox"/> N/A <input checked="" type="checkbox"/>	Standard number and issue year: AS/NZS 60598.2.5:2002 Edition / Amendment status: - Standard title: Luminaires - Particular requirements - Floodlights AS/NZS ZZ modified Yes <input type="checkbox"/> No <input type="checkbox"/> N/A <input checked="" type="checkbox"/>
OR Complies with the Conformity Cooperation Agreement ⁵ Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	




Names and addresses of any testing organisation or body

Name(s): Guangdong Keyway Testing Technology Co., Ltd.	Address(es): Baishun Industrial Zone, Zhangmutou Town, Dongguan, Guangdong, China
Name(s):	Address(es):

Reference to relevant test reports/certification and the issue date that show how compliance is achieved

Standard(s) or document(s) used, to show how compliance with cited standard is achieved: Test report: IEC 60598-1:2014 in conjunction with IEC 60598-2-5:2015 with AS/NZS national variations of AS/NZS 60598.1:2013 in conjunction with AS/NZS 60598.2.5:2002 (To be used with approved LED Driver: HLG-185H-36A)	Report Certification or Document reference N°(s): 17KWS020125L	Issue date(s): 10.03.2017
Reference to any management quality system involved: -		
Additional information ⁶ : Comply with schedule 4 requirements		

Declaration (signed for and on behalf of)

Name and position as authorized by the issuer ⁷ : Dr. Gouda, Director	Signature: 
Issuer Identification (as affixed to the article):  	Date: 27. 3. 2018